

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Camille Bauer Metrawatt AG

Aargauerstrasse 7, 5610 Wohlen, Switzerland

the Certificate No: **Z01620** for the PROFIBUS device:

Model Name: APLUS
 Revision: Rev. A; SW/FW: --/BU:V1.0_Rev.61; HW: Rev. 2
 GSD: CAACCB.GSD, File Version: 1.4

This certificate confirms that the product has successfully passed the certification tests with the following scope:

| | |
|--|---|
| <input checked="" type="checkbox"/> DP-V0 | MS0, Sync, Freeze, Set_Slave_Add, Fail_Safe |
| <input checked="" type="checkbox"/> Physical Layer | RS485 |

Test Report Number: 156-01
 Authorized Test Laboratory: ifak, Magdeburg, Germany

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Slaves, Version 3.0.9 from September 2008".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **July 15, 2023** the certificate is valid for life.

Karlsruhe, August 31, 2020

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)



(Dr. Jörg Hähnliche)

