


Firmware history

Release Notes

LINAX PQ5000CL



Update of PQ5000CL

The update package of the PQ5000CL contains two firmware images, one for the base unit and the other one for the CL option, which enables communication with the current modules via the Current Link. The firmware update should be performed in the following way:

1. Possible upgrade of the updater if not working with the EasyUpdater
2. Update of the firmware of the base unit
3. Update of the firmware of the CL option

GMC INSTRUMENTS

Camille Bauer Metrawatt AG
Aargauerstrasse 7
CH-5610 Wohlen / Schweiz
Telefon: +41 56 618 21 11
Telefax: +41 56 618 35 35
E-Mail: info@cbmag.com

 **CAMILLE BAUER**

Version	Change log
V3.08 – 9588 (2023/05/24)	Fixes • Possible problems when current modules are not connected
V3.08 – 9588 (2023/05/16)	New features • Flicker measurement Pst and Plt • Configurable mains signalling voltage • Access to energy meters via Modbus Fixes • Regular update of serial-no. timestamp in IEC61850 • IEC61000-2-4 class 3: Wrong limit value for 15th voltage harmonic • PQDIF files contained unmeasured data • Power factor calculation
V3.04 – 9487 (2023/02/23)	New features • Support for device version in field housing without display • Support for GPS time synchronization
V3.04 – 8854 (2022/09/22)	Official product release of LINAX PQ5000CL standard version
V3.01 – 7444 (2021/09/29)	Official product release of LINAX PQ5000CL NLB version